

# Baker Chemical Injector

Model 1500  
(patent pending)

Flow in GPM	Pitot Reading	Turns Open	Chemical Feed in GPH	Chemical Feed in GPM
1300	60	5	90	1.50
		4	87	1.45
		3	83	1.38
		2	65	1.08
		1	33	0.55
1190	50	5	90	1.5
		4	87	1.45
		3	83	1.38
		2	65	1.08
		1	33	0.55
1060	40	5	90	1.50
		4	87	1.45
		3	83	1.38
		2	65	1.08
		1	33	0.55
920	30	5	90	1.50
		4	87	1.45
		3	83	1.38
		2	65	1.08
		1	33	0.55
750	20	5	72	1.20
		4	64	1.07
		3	58	0.97
		2	46	0.77
		1	23	0.38
530	10	5	31	0.52
		4	30	0.50
		3	28	0.47
		2	22	0.37
		1	10	0.17